

PRE BID Query RESPONSE TPNODL-LA-OT-207

S No	Clause No.	Tender Clause Details	Details of Deviation with Justification	TPNODL response
1	Page3(9) ENG_HV_0 3 6 Clause 4.0	Arrester type - Distribution	Kindly clarify LA is required of distribution type or stationtype.	Class-II, station class Arresters
2		Surge counter/Monitor	Whether Surge Monitor required for both 11kV 10kA Station class LA and 33kV 10kA Station class LA	Surge counter/Monitor along with necessary insulator support and earthing need to be provided for both 33KV and 11KV station class LA
3	TS ENG_HV_0 3 6 Clause 11.0 & GCC 13.0	Guarantee	The guarantee of the offered materials shall be for 12 months from the date of commissioning or 18 months from the date of actual supply (Invoice or receipt date at stores)whichever is earlier and not from the final supplies. However, LA being a protective Equipments latent defect for additional period of three years cannot be applicable. Over all guarantee shall be as 12 months from the date of commissioning or 18 months from the date of actual supply whichever is earlier.	As per Tender Only
4	GC C 13. 4	Cost of Repairs.	Not in our scope. Any & All type of Liabilities or Costs & Expenses incurred towards installation, removal, refixingwhether for repairs & replacements are not in our scope. Scope of Guarantee is limited to the replacement of defective (for any manufacturing Defects within the Gurantee period) materials at supply stores.	Ok
5	GCC 13.5	Guarantee period for Goods Outsourced	Not Applicable and hence not acceptable.	Ok
6	GCC 13.6	Latent Defect	Not Applicable and hence not acceptable.	As per Tender Only
7	GC C 13. 7	Support beyond the Guarantee Period	The lightning arresters are a single unit and has no accessories with it hence this clause is not acceptable.	As per actual cost if required with mutual concern.