



Response to Pre-Bid Queries

Tender Enquiry No. TPNODL/OT/2021-22/169Dtd. 09.02.2022

Tender Description: Purchase Order for supply of Fire Extinguishers and Fire Bucket

The pre-bid queries as received against the referred tender enquiry and TPNODL's responses on the same are placed below:

S. No.	Tender Reference	Bidder's Pre-Bid Query	TPNODL's Response
01.	Fire bucket as per ISI Marked, IS: 2546-1974. Stand with canopy	Kindly share detailed dimension, design / drawing or image of Fire Bucket. Also provide image and design / drawing of Stand, since it is a customized product. Request for	Canopy height shall be more than 5.5 feet height and sufficient strength to take load of 4 buckets with sand. It should be not be toppled in windy condition or while removing bucket. Details of canopy drawing with material shall be share by the business associate during bid document.
02.	Page 05 & 06 of 09 ABC type 50 kgs & 25 kgs Fire Extinguisher-IS - 10658	IS 10658 is not the current standard. IS 16018 is the current standard of higher capacity fire extinguishers. Hence, kindly confirm and amend the same.	Follow IS 16018
03.	Page 06 of 09 ABC type 25 kgs Fire Extinguisher	The complete spec provided against 25 kg DCP fire extinguisher is of 50 kg. Various parameters of the specification differs from 25 kg and 50 kg such as Capacity of External Co2, Discharge time, Tare Weight, Full weight etc. Hence, Kindly confirm and amend the same accordingly.	1kg CO2 for 25 KG and 2 KG for 50 kg.
04.	Page 06 of 09 Fire Bucket (ISI Marked)	Since Fire Bucket is not a performance based product and only a couple of OEM have BIS approval for the same in India, we would be quoting for Fire Buckets as per IS 2546 WITHOUT ISI MARK. Hence, please confirm the same.	ISI marked bucket required
05.	Page 08 of 09 Tender Sample Clause – One sample provide for assessment	Requesting you to kindly confirm whether sample clause if compulsory for qualification and if yes then by what date / time the sample should be delivered as we can only dispatch the sample once we get clarification against above queries and it usually takes a 7-10 days transit duration for delivering the samples.	Sample is required
06	Evaluation Criteria	Kindly update us on the evaluation criteria – i.e. if the evaluation would on overall basis or item wise basis.	All Overall BOQ basis.



Response to Pre-Bid Queries

Tender Enquiry No. TPNODL/OT/2021-22/169Dtd. 09.02.2022

Tender Description: Purchase Order for supply of Fire Extinguishers and Fire Bucket

07	5.18 – Acrylic sign board with eco vinyl of size 1x1 square feet each and thickness of acrylic board of 5mm. Quantity of sign board as per order quantity of extinguishers and as per the capacity and type of extinguisher. Letter will be white colour and rest of sign board will be red colour.	Please provide creative Acrylic sign board	Required as per specification mentioned in bid documents.
08.	Fire bucket as per ISI Marked, IS: 2546-1974. Stand with canopy.	Fire bucket with stand 960 set or 240 set that is (4 bucket with stand equal to total 960 bucket and 240 stand that is 240 set) or (4 bucket with stand equal to total 3840 bucket and 960 stand total sets)	240 stand and 960 buckets. 1 set is 4 buckets with one stand.
09.	5.19- All extinguishers and fire sign boards to be installed at 250 locations at district of Balasore, Baripada, Bhadrak, Jajpur and Keonjhar within one month from the date of receiving fire extinguisher at store of Balasore.	We would request you to kindly confirm if only the supply of fire extinguishers is under vendor's scope or even its installation falls under vendor's scope as stated above.	As mentioned in 5.19 in tender documents.

Note: - This document shall form an integral part of tender and should be submitted along with the tender document.